



ADDENDUM NO. 1

BY: **GBBN Architects, Inc.**
332 East Eighth
Street Cincinnati,
Ohio 45202
513.241.8700

SUBJECT: **Miami University - King Library Window Replacement**
Edward King Library
151 S. Campus Ave.
Oxford, OH 45056

TO: **All Bidders of Record**

Acknowledge receipt of this Addendum by inserting its number and date in the space provided on the Bid Form. Failure to do so may subject bidders to disqualification. This Addendum forms a part of the Bidding Documents and revises the Bidding Documents as follows:

RFI's

1.1 Question: *You have lami indicated in GL-02 – do you really require lami? If so do you have the makeup you need? This is add additional cost to the job and want to make sure it is necessary.*

Response: Laminated glass is required. Refer to Project Manual Section 08 80 00, GL-02 for specified laminated glazing for the interior lite of glass.

1.2 Question: *We will not provide film to put on the interior glazing. Also, we may need to temper the glass to help with any heat gain. We will follow the cardinal requirements for tempering.*

Response: Window film is to be provided and installed as specified. If the glass is required by the manufacturer to be tempered in the locations where the film is applied, that should be included in the submitted bid.

DRAWINGS

1.1 No changes are required to the Drawings.

ATTACHMENTS

1.1 Sign-in sheet from the Pre-Bid Meeting held on August, 24 2022 is attached

END OF ADDENDUM NO.1

