

MIAMI UNIVERSITY
OFFICE OF FACILITIES CONTRACTING
OXFORD, OHIO 45056

NOTICE TO BIDDERS

ADDENDUM #1

SCP FREE COOLING IMPROVEMENTS

Please note the following items which become part and parcel to the Contract Documents and shall be considered when bidding.

ITEM 1: Addition of Alternate 1 with its Estimate of \$45,000

Alternate 1 was inadvertently omitted from the original Bid Form and Bid announcement materials. Alternate 1 consists of the removal of an existing pneumatic control panel, and associated pneumatic tubing and controls (as shown on the Specifications/Drawings). A portion of the removed controls will be replaced by DDC controls (by Siemens).
A Revised Bid Form is being issued with this Addendum 1 to reflect the inclusion of Alternate 1. The Revised Bid Form must be used for Bid submissions.

ITEM 2: Revised Bid Form

A Revised Bid form, reflecting Alternate 1, is attached and must be used for Bid submissions.

ITEM 3: Questions and Answers

The following single question, with its corresponding Answer, has been received:

- q. Can the CHW system be isolated and drained to make the tie-in to it?
 - a. No. The plant must continue to distribute CHW throughout construction. The connections to the existing CHW mains must be done by hot-tap, allowing the plant to continue to operate.

ITEM 4: Pre-Bid Meeting Attendee Sheet

The attendee list regarding the project's Pre-bid Meeting is attached.

The Project Bid Documents, Addendum # 1 and a list of the current Plan Holders may be found at www.pfd.miamioh.edu/fco.

***Please note receipt of this Addendum 1 on the Bid Form.**

Betsy Davidson

Director, Facilities Contracting Office

July 22, 2022